


# Municipal wastewater treatment by microsieving, microfiltration and forward osmosis

Concepts and potentials


TOBIAS HEY  
FACULTY OF ENGINEERING | LUND UNIVERSITY




# Introduction

Municipal wastewater treatment

- Urbanisation: 50% already live in cities → 2/3 in 2050
- Increase in wastewater which needs treatment to protect nature and human from adverse effects
- Wastewater is treated at wastewater treatment plants requiring energy and space
- In Sweden: 95% of sewage is treated by 411 wastewater treatment plants. 50% of these WWTPs are in the size of 2 000 – 10 000 PE.
- In the future space may become limiting and more energy is required to accommodate future wastewater loads
- This study investigates the feasibility to treat municipal wastewater without involving the biological treatment step in the main stream process.



Västra Syd Källby  
Avlopps- & Reningsverk



**Aims and objectives**

**‘Provide proof-of-concept for treating municipal wastewater without biological treatment step to use different separation techniques.’**

**Specific objectives:**

- To test different treatment concepts
- To operate microfiltration without backflushing
- To investigate the effects of coagulation and flocculation
- To identify and evaluate suitable treatment configuration(s)

# Background

Municipal wastewater

Direct membrane filtration




# Municipal wastewater

Particles

Soluble components

Water (H<sub>2</sub>O)




Jin *et al.* (2015)

# Direct membrane filtration

Background

# Direct membrane filtration (DMF)




- Part of the COD fraction consists of particulate organic matter which can be separated with membrane(s) and utilised for biogas production in one step

Wastewater

Microsieve

Microfiltration


Particles (>100 μm)  
Particles (>0.2 μm)  
Soluble components  
Water (H<sub>2</sub>O)



# Pilot plant and bench scale

At the Källby wastewater treatment plant

Wastewater flow direction



Coagulation

Flocculation



MS


MF

FO



Sand trap





Incoming feed to the pilot plant

To the MF-unit

Stirrer


Stirrer

Overflow

Coagulation

Flocculation

To the MS-unit





**Drum**

**Filter cloth**

**Motor**


TF







# Conducted experiments and Results


# Mechanical pre-treatment



# Mechanical pre-treatment



# Physico-chemical pre-treatment



# Results



	BOD <sub>7</sub> (mg·L <sup>-1</sup> )	SS (mg·L <sup>-1</sup> )	CODt (mg·L <sup>-1</sup> )	TNt (mg·L <sup>-1</sup> )	NH <sub>4</sub> -N (mg·L <sup>-1</sup> )	TPt (mg·L <sup>-1</sup> )	J <sub>w</sub> (L·m <sup>-2</sup> ·h <sup>-1</sup> ) (L·m <sup>-2</sup> ·h <sup>-1</sup> ·bar <sup>-1</sup> )
Mechanical	17±5	0±0	73±27	37±10	32±5	2.4±0.6	2.6 87
Coagulation	11±2	0±0	41±11	42±4	41±4	0.2±0.3	6.2 207
Flocculation(+)	13±2	0±0	48±6	36±6	36±6	2.4±1	2.6 87
Coagulation + anionic polymer	16±13	0±0	41±26	34±10	34±11	<0.03	6.1 203
Coagulation + cationic polymer	13±2	0±0	44±10	30±6	30±6	<0.03	2.9 97



**Discharge limit for WWTPs ≤ 10 000 p.e.: BOD<sub>7</sub>: 15 mg/L, Tot-P: 0.5 mg/L**

# Concept evaluations


Selected concepts and evaluated Results



# Direct membrane filtration





Energy-/electricity consuming




Energy-/electricity producing

# Direct forward osmosis





**Energy-/electricity consuming**




**Energy-/electricity producing**

# Anaerobic digestion



Energy-/electricity consuming




Energy-/electricity producing

Specific electricity, energy and  
area demand

<b>Wastewater treatment plant</b>	<b>Size</b>	<b>Specific electricity consumption</b>	<b>Specific area demand</b>
	PE	$\text{kWh}_{\text{el}} \cdot \text{m}^{-3}$	$\text{m}^2 \cdot \text{PE}^{-1}$
<b>Sjölunda</b>	370 000	0.42	0.107
<b>Källby</b>	100 000	0.41	0.155
<b>Klagshamn</b>	60 000	0.45	0.132
<b>Direct membrane filtration</b>	10 000	0.55	0.046
<b>Södra Sandby</b>	7 900	0.84	0.228
<b>Veberöd</b>	4 800	0.77	0.190

# Specific electricity consumption




# Net electricity and energy outcome of the DMF concept

	Specific electricity net surplus		Specific heat net surplus	
	$\text{kWh}_{\text{el}} \cdot \text{PE}^{-1} \cdot \text{year}^{-1}$	$\text{Wh}_{\text{el}} \cdot \text{m}^{-3}$	$\text{kWh} \cdot \text{PE}^{-1} \cdot \text{year}^{-1}$	$\text{kWh} \cdot \text{m}^{-3}$
<b>Direct membrane filtration (Coagulation, flocculation)</b>	1	14	43	0.6

Specific area demand





Södra Väst kustvägen

E20

20

E6

E20

E6



Strandvägen

Vinstorpsvägen

Vinstorpsvägen

Lomma

LOMMA

10 000 PE

KARSTORP

Karstorp vägen

STRANDHUSEN

Malmövägen

Malmövägen

Järdsvägen



**Källby WWTP**  
**1550 m<sup>2</sup>**

**DMF**  
**551 m<sup>2</sup>**

Strandpromenaden  
Sjögatan  
Sjögatan  
Sjögatan  
Sjögatan  
Sjögatan  
Kryssgränd  
Kryssgränd  
Lovartsgränd

# Conclusions

# **‘The Swedish discharge demands for small- and medium-sized wastewater treatment plants can be met without using biological treatment’**

- More carbon can be retained and more electricity and energy can be generated
- The direct membrane filtration concept indicated to be net electricity and energy neutral/positive
- Municipal wastewater can be treated on a smaller footprint
- The direct membrane filtration concept can be used up to 10 000 PE

# Direct membrane filtration



- Coagulant and flocculant are necessary for high permeate flux and to comply discharge demands
- Available for full-scale installation
- Air scouring consumes most electricity

Do we have time for  
Future music?



# Forward osmosis


Background

# Forward osmosis









Gearing pumps

Computer

Computer

Draw

Draw

Feed

Feed

Electronic balance


Membrane module

Electronic balance

Membrane module

# Conducted experiments and Results

# Mechanical pre-treatment




# Results: Mechanical pre-treatment

Parameter	Raw MWW	Microsieve filtrate	Microfiltration permeate
$J_w$ ( $L \cdot m^{-2} \cdot h^{-1}$ )	9.3	9.3	10.0
$BOD_7$ ( $mg \cdot L^{-1}$ )	1.1	0.3	0.4
$TN_t$ ( $mg \cdot L^{-1}$ )	38	27	41
$TN_f$ ( $mg \cdot L^{-1}$ )	38	26	41
$TP_t$ ( $mg \cdot L^{-1}$ )	0.15	0.03	0.04
$TP_f$ ( $mg \cdot L^{-1}$ )	0.03	0.03	0.04

Discharge limit for WWTPs  $\leq 10\ 000$  p.e.:  $BOD_7$ : 15 mg/L, Tot-P: 0.5 mg/L

# Physico-chemical pre-treatment



# Results: Physico-chemical pre-treatment

Parameter	PACl		Cationic polymer		PACl + anionic polymer		PACl + cationic polymer	
	MSF	MFP	MSF	MFP	MSF	MFP	MSF	MFP
$J_w$ (L·m <sup>-2</sup> ·h <sup>-1</sup> )	8.9	11.0	9.0	10.9	9.8	12.0	8.7	9.2
BOD <sub>7</sub> (mg·L <sup>-1</sup> )	7	3	21	14	5	5	18	16
TNt (mg·L <sup>-1</sup> )	19	32	11	26	13	13	14	18
TNf (mg·L <sup>-1</sup> )	19	30	12	26	35	35	13	19
TPt (mg·L <sup>-1</sup> )	0.06	0.05	0.1	0.05	0.05	0.04	0.05	<0.03
TPf (mg·L <sup>-1</sup> )	0.06	0.05	0.1	0.05	0.05	0.04	0.05	<0.03

Discharge limit for WWTPs ≤ 10 000 p.e.: BOD<sub>7</sub>: 15 mg/L, Tot-P: 0.5 mg/L

# Results (2M NaCl)

Parameter	Mechanical	PACl	PACl + anionic polymer
	MSF	MSF	MSF
$J_w$ (L·m <sup>-2</sup> ·h <sup>-1</sup> )	9.3	8.9	9.8
BOD <sub>7</sub> (mg·L <sup>-1</sup> )	0.3	7	5
TNt (mg·L <sup>-1</sup> )	27	19	13
TNf (mg·L <sup>-1</sup> )	26	19	35
TPt (mg·L <sup>-1</sup> )	0.03	0.06	0.05
TPf (mg·L <sup>-1</sup> )	0.03	0.06	0.05



# Direct forward osmosis: Summary (Seawater)

Parameter	Mechanical	PACI	PACI + anionic polymer
	MSF	MSF	MSF
$J_w$ ( $L \cdot m^{-2} \cdot h^{-1}$ )	1.1	1.5	1.4
$BOD_7$ ( $mg \cdot L^{-1}$ )	1.6	3.7	6.7
TPt ( $mg \cdot L^{-1}$ )	0.02	0.02	0.02
TPf ( $mg \cdot L^{-1}$ )	0.02	0.02	0.05

# DMF Vs. DFO Results

<b>Wastewater treatment plant</b>	<b>Size</b>	<b>Specific electricity consumption</b>	<b>Specific area demand</b>
	PE	$\text{kWh}_{\text{el}} \cdot \text{m}^{-3}$	$\text{m}^2 \cdot \text{PE}^{-1}$
<b>Sjölunda</b>	370 000	0.42	0.107
<b>Källby</b>	100 000	0.41	0.155
<b>Klagshamn</b>	60 000	0.45	0.132
<b>DMF</b>	10 000	0.55	0.046
<b>DFO (Öresund)</b>	10 000	0.55	0.051
<b>Södra Sandby</b>	7 900	0.84	0.228
<b>Veberöd</b>	4 800	0.77	0.190

# Net outcome of the DMF and DFO concepts

	Specific electricity net surplus		Specific heat net surplus	
	$\text{kWh}_{\text{el}} \cdot \text{PE}^{-1} \cdot \text{year}^{-1}$	$\text{Wh}_{\text{el}} \cdot \text{m}^{-3}$	$\text{kWh} \cdot \text{PE}^{-1} \cdot \text{year}^{-1}$	$\text{kWh} \cdot \text{m}^{-3}$
<b>Direct membrane filtration (Coagulation, flocculation)</b>	1	14	43	0.6
<b>Direct forward osmosis (Öresund)</b>	4	55	58	0.8